

City of Bird Island
Water Drainage/Inflow & Infiltration/Back Up Progress Updates

Friday, December 8, 2017

- The catch basin addition redirection on Highway 212 and 4th Street has been completed.
- Televising report has been received, read, and video partially viewed. There was no evidence of a cross connection.
- Smoke testing will be done near 9th Street and Grove Avenue.
- Discharging of pond water has stopped due to frozen receiving waters. Current pond level is adequate to marginal in relation to the ability to hold all sanitary water until April.

The next report will be on smoke testing results when completed.